

| Sample Number | School | Floor | Location/Classroom # | First Sample Date | First Sample Results (in parts per billion) | Remediation Response -- Required for any outlet > 15 parts per billion | Resampling Dates -- Required After Remediation Response | Passing/Clearance Results -- (in parts per billion; must be ≤ 15) | Is Outlet in Compliance? | Passing/Clearance Date | Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption |
|---------------|--------|-------|--|-------------------|--|---|---|---|--------------------------|------------------------|---|
| 2021-SOMS-001 | SOMS | 3 | 3rd Floor by Girls Bathroom (across from Library) Water Cooler Fountain (Combo Unit) - Mouth | 5/26/21 | <1.0 | Not Required | Not Required | <1.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-002 | SOMS | 3 | 3rd Floor by Girls Bathroom (across from Library) Water Cooler Fountain (Combo Unit) - Bottle Filler | 5/26/21 | <1.0 | Not Required | Not Required | <1.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-003 | SOMS | 3 | Library Makers Space Sink Faucet | 5/26/21 | 7.8 | Not Required | Not Required | 7.8 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-004 | SOMS | 2 | 2nd Floor Main Entrance Lobby Water Cooler Fountain (Combo Unit) -Mouth | 5/26/21 | <1.0 | Not Required | Not Required | <1.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-005 | SOMS | 2 | 2nd Floor Main Entrance Lobby Water Cooler Fountain (Combo Unit) -Bottle Filler | 5/26/21 | <1.0 | Not Required | Not Required | <1.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-006 | SOMS | 2 | Hallway Across from Room 235 Bubbler Water Fountain | 5/26/21 | 31.0 | Outlet was permanently removed from service; was replaced with a new water fountain which has passed testing. | Not Required | Not Applicable | Not Applicable | Not Applicable | Not Applicable |
| 2021-SOMS-007 | SOMS | 2 | Room 226- Staff Lounges Sink Faucet | 5/26/21 | <1.0 | Not Required | Not Required | <1.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-008 | SOMS | 2 | Duplicate | VOID | VOID | VOID | VOID | VOID | VOID | 5/26/21 | Not Applicable |
| 2021-SOMS-009 | SOMS | 1 | Outside Girls Locker Room Water Cooler (Combo Unit) - Mouth | 5/26/21 | <1.0 | Not Required | Not Required | <1.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-010 | SOMS | 1 | Outside Girls Locker Room Water Cooler Fountain (Combo Unit) - Bottle Filler | 5/26/21 | <1.0 | Not Required | Not Required | <1.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-011 | SOMS | 1 | Boys Locker Room Water Cooler Fountain (Combo Unit) - Mouth | 5/26/21 | <1.0 | Not Required | Not Required | <1.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-012 | SOMS | 1 | Boys Locker Room Water Cooler Fountain (Combo Unit) -Bottle Filler | 5/26/21 | <1.0 | Not Required | 6/22/2021 | <1.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-013 | SOMS | 1 | 1ST Floor Classroom 175 Sink (left when facing) | 5/26/21 | 25.0 | Outlet temporarily shut down; filter to be installed then resampled. | 6/22/2021 | Pending | Pending | Pending | Not Applicable |
| 2021-SOMS-014 | SOMS | 1 | 1ST Floor Classroom 175 (Middle Sink) | 6/22/2021 | Pending | Outlet temporarily shut down; filter to be installed then resampled. | Pending | Pending | Pending | 5/26/21 | Not Applicable |
| 2021-SOMS-015 | SOMS | 1 | 1ST Floor Classroom 175 (Right when facing) | 6/22/2021 | Pending | Outlet temporarily shut down; filter to be installed then resampled. | Pending | Pending | Pending | 5/26/21 | Not Applicable |
| 2021-SOMS-016 | SOMS | 1 | 1ST Floor Classroom 179 (Home Ec) Sink (left when facing) Faucet 1 | 5/26/21 | 44.9 | Outlet temporarily shut down; filter to be installed then resampled. | 6/22/2021 | Pending | Pending | Pending | Not Applicable |
| 2021-SOMS-017 | SOMS | 1 | 1st Floor Classroom 179 (Home Ec) Sink (middle when facing) Faucet 2 | 5/26/21 | 11.8 | Not Required | Not Required | 11.8 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-018 | SOMS | 1 | 1st Floor Classroom 179 (Home Ec) Sink (right when facing) Faucet 3 | 5/26/21 | 14.9 | Not Required | Not Required | 14.9 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-019 | SOMS | 1 | 1ST Floor Classroom 181 (Reading Room) Sink Faucet | 5/26/21 | 91.7 | Outlet temporarily shut down; filter to be installed then resampled. | 6/22/2021 | Pending | Pending | Pending | Not Applicable |

| | | | | | | | | | | | |
|---------------|------|---|--|---------|-------|---|--------------|----------------|----------------|----------------|--|
| 2021-SOMS-020 | SOMS | 1 | Room 153 (Shop) Single Sink (east wall) Faucet | 5/26/21 | 8.1 | Not Required | Not Required | 8.1 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-021 | SOMS | 1 | Room 153 (Shop) Single Sink (west wall) Faucet | 5/26/21 | 2.8 | Not Required | Not Required | 2.8 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-022 | SOMS | 1 | Classroom 151 (Shop) Single Sink Faucet | 5/26/21 | 4.4 | Not Required | Not Required | 4.4 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-023 | SOMS | 1 | Nurses Room Sink Faucet (left when facing) | 5/26/21 | 10.0 | Not Required | Not Required | 10.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-024 | SOMS | 1 | Nurses Sink Faucet (middle when facing) | 5/26/21 | 8.0 | Not Required | Not Required | 8.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-025 | SOMS | 1 | Nurses Sink Faucet (right when facing) | 5/26/21 | 17.2 | Outlet temporarily shut down; aerator to be replaced then resampled. | 6/22/2021 | 11 | Yes | 6/22/2021 | Not Applicable |
| 2021-SOMS-026 | SOMS | 1 | Inside Cafeteria (near exit door to parking lot)- Water Cooler Fountain | 5/26/21 | 114.0 | Outlet was permanently removed from service; was replaced with a new water fountain which has passed testing. | Not Required | Not Applicable | Not Applicable | Not Applicable | Not Applicable |
| 2021-SOMS-027 | SOMS | 1 | Inside Cafeteria (near hallway) Water Cooler Fountain | 5/26/21 | 4.2 | Outlet was permanently removed from service | Not Required | 4.2 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-028 | SOMS | 1 | Kitchen Ice Machine | 5/26/21 | <1.0 | Not Required | Not Required | <1.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-029 | SOMS | 1 | Kitchen Island Single Sink Faucet | 5/26/21 | 6.0 | Not Required | Not Required | 6.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-030 | SOMS | 1 | Kitchen Double Sink Faucet 1 (left when facing) | 5/26/21 | 21.4 | Outlet temporarily shut down; filter to be installed then resampled. | 6/22/2021 | Pending | Pending | Pending | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-031 | SOMS | 1 | Kitchen Double Sink Faucet 2 (right when facing) | 5/26/21 | 4.4 | Not Required | Not Required | 4.4 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-032 | SOMS | 1 | Kitchen Single Sink | 5/26/21 | 5.3 | Not Required | Not Required | 5.3 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-033 | SOMS | 1 | Kitchen Small Handwashing Sink Faucet (Near Server Line) | 5/26/21 | 5.3 | Not Required | Not Required | 5.3 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-034 | SOMS | 1 | Pool Locker Hallway Water Cooler Fountain Single Unit (upper) | 5/26/21 | <1.0 | Not Required | Not Required | <1.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-035 | SOMS | 1 | Pool Locker Hallway Water Cooler Fountain (lower) Combo Unit-Mouth | 5/26/21 | <1.0 | Not Required | Not Required | <1.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-036 | SOMS | 1 | Pool Locker Hallway Water Cooler Fountain (lower) Combo Unit-Bottle | 5/26/21 | <1.0 | Not Required | Not Required | <1.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-037 | SOMS | 1 | Inside Pool Room Single Water Cooler Fountain (upper unit) | 5/26/21 | <1.0 | Not Required | Not Required | <1.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-038 | SOMS | 1 | Inside Pool Room Single Water Cooler Fountain (lower combo unit)-Mouth | 5/26/21 | <1.0 | Not Required | Not Required | <1.0 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-039 | SOMS | 1 | Inside Pool Room Single Water Cooler Fountain (lower combo unit)-Bottle Filler | 5/26/21 | <1.0 | Not Required | Not Required | <1.0 | Yes | 5/26/21 | Not Applicable |

| | | | | | | | | | | | |
|---|------|---|--|-------------|----------------------------------|----------------|----------------|----------------|----------------|----------------|--|
| 2021-SOMS-040 | SOMS | 1 | Band Room Sink Faucet | 5/26/21 | 2.4 | Not Required | Not Required | 2.4 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-041 | SOMS | 1 | Orchestra Room Sink Faucet | 5/26/21 | 8.2 | Not Required | Not Required | 8.2 | Yes | 5/26/21 | Not Applicable |
| 2021-SOMS-042 | SOMS | 1 | Four Corners Hallway Water Cooler (Combo Unit) - Mouth | 6/9/22 | <1.0 | Not Required | Not Required | <1.0 | Yes | 6/9/2022 | Not Applicable |
| 2021-SOMS-043 | SOMS | 1 | Four Corners Hallway Water Cooler (Combo Unit) - Bottle Filler | 6/9/22 | <1.0 | Not Required | Not Required | <1.0 | Yes | 6/9/2022 | Not Applicable |
| 2021-SOMS-044 | SOMS | 1 | Bubbler Water Fountain in Hallway directly Outside Cafeteria | Not Sampled | Permanently Removed from Service | Not Applicable | Not Applicable | Not Applicable | Not Applicable | Not Applicable | Permanently Removed from Service |
| 2021-SOMS-045 | SOMS | 1 | Hallway Next Boys Room/170 Water Cooler (Combo Unit) - Mouth | 6/9/22 | <1.0 | Not Required | Not Required | <1.0 | Yes | 6/9/2022 | Not Applicable |
| 2021-SOMS-046 | SOMS | 1 | Hallway Next Boys Room/170 Water Cooler (Combo Unit) - Bottle Filler | 6/9/22 | <1.0 | Not Required | Not Required | <1.0 | Yes | 6/9/2022 | Not Applicable |
| 2021-SOMS-047 | SOMS | 1 | Hallway Next Girls Room/172 Water Cooler (Combo Unit) - Mouth | 6/9/22 | <1.0 | Not Required | Not Required | <1.0 | Yes | 6/9/2022 | Not Applicable |
| 2021-SOMS-048 | SOMS | 1 | Hallway Next Girls Room/172 Water Cooler (Combo Unit) - Bottle Filler | 6/9/22 | <1.0 | Not Required | Not Required | <1.0 | Yes | 6/9/2022 | Not Applicable |
| 2021-SOMS-049 | SOMS | 2 | Hallway Next to Boys Room 234 Water Cooler (Combo Unit) - Mouth | 6/9/22 | <1.0 | Not Required | Not Required | <1.0 | Yes | 6/9/2022 | Not Applicable |
| 2021-SOMS-050 | SOMS | 2 | Hallway Next to Boys Room 234 Water Cooler (Combo Unit) - Bottle Filler | 6/9/22 | <1.0 | Not Required | Not Required | <1.0 | Yes | 6/9/2022 | Not Applicable |
| 2021-SOMS-051 | SOMS | 2 | Hallway Next to Girls Room 236 Water Cooler (Combo Unit) - Mouth | 6/9/22 | <1.0 | Not Required | Not Required | <1.0 | Yes | 6/9/2022 | Not Applicable |
| 2021-SOMS-052 | SOMS | 2 | Hallway Next to Girls Room 236 Water Cooler (Combo Unit) - Bottle Filler | 6/9/22 | <1.0 | Not Required | Not Required | <1.0 | Yes | 6/9/2022 | Not Applicable |
| 2021-SOMS-053 | SOMS | 1 | Cafeteria Water Cooler (Combo Unit) - Mouth | 6/9/22 | <1.0 | Not Required | Not Required | <1.0 | Yes | 6/9/2022 | Not Applicable |
| 2021-SOMS-054 | SOMS | 1 | Cafeteria Water Cooler (Combo Unit) - Bottle Filler | 6/9/22 | <1.0 | Not Required | Not Required | <1.0 | Yes | 6/9/2022 | Not Applicable |
| Non-Applicable Outlets Below (these are outlets that were determined by the District to not be used for cooking or drinking by staff or students.) | | | | | | | | | | | |
| 2021-SOMS-042 | SOMS | 3 | 3rd Floor Hallway by Staff/Gender Neutral-Bathroom Sink Faucet | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-043 | SOMS | 3 | 3RD Floor Custodial/Roof Access Room - Slop Sink | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-044 | SOMS | 3 | 3RD Floor Classroom 309, Left to Right, Lab Sink 1 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-045 | SOMS | 3 | 3RD Floor Classroom 309, Left to Right, Lab Sink 2 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |

| | | | | | | | | | | | |
|---------------|------|---|--|-------------|-------------|-------------|-------------|-------------|-------------|----------------|--|
| 2021-SOMS-146 | SOMS | 1 | 1st Floor Classroom 187 (Art Room) Sink (closest to door) Faucet 2 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-147 | SOMS | 1 | 1st Floor Classroom 189 (Art Room) Sink (closest to phone) Faucet 1 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-148 | SOMS | 1 | 1st Floor Classroom 189 (Art Room) Sink (closest to door) Faucet 2 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-149 | SOMS | 1 | Girls Athletic Office Bathroom Sink Faucet | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-150 | SOMS | 1 | Boys Pool Locker Rooms Bathroom Single Sink (left when facing) Faucet 1 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-151 | SOMS | 1 | Boys Pool Locker Rooms Bathroom Single Sink (middle) Faucet 2 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-152 | SOMS | 1 | Boys Pool Locker Rooms Bathroom Single Sink (right when facing) Faucet 3 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-153 | SOMS | 1 | Pool Gender Neutral Bathroom Faucet | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-154 | SOMS | 1 | Pool Area Custodial Room Slop Sink | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-155 | SOMS | 1 | Girls Pool Locker Rooms Bathroom Single Sink (left when facing) Tempered Faucet 1 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-156 | SOMS | 1 | Girls Pool Locker Rooms Bathroom Single Sink (middle) Tempered Faucet 2 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-157 | SOMS | 1 | Girls Pool Locker Rooms Bathroom Single Sink (right when facing) Tempered Faucet 3 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-158 | SOMS | 1 | Boys Gym Locker Room Bathroom Sink (left when facing) Tempered Faucet 1 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-159 | SOMS | 1 | Boys Gym Locker Room Bathroom Sink (left when facing) Faucet 2 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-160 | SOMS | 1 | Bathroom Sink (left when facing) in Girls Locker Room (by Gym) Faucet 1 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-161 | SOMS | 1 | Bathroom Sink (left when facing) in Girls Locker Room (by Gym) Faucet 2 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-162 | SOMS | 1 | Bathroom Sink (left when facing) in Girls Locker Room (by Gym) Faucet 3 | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-163 | SOMS | 1 | 1st Floor - Bathroom Sink Faucet by Custodial Break Room | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-164 | SOMS | 1 | All Eyewash Stations in School | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-165 | SOMS | 1 | All Showers in Girls Locker Rooms | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |

| | | | | | | | | | | | |
|--|------|---|---|-------------|-------------|-------------|-------------|-------------|-------------|----------------|--|
| 2021-SOMS-166 | SOMS | 1 | All Showers in Boys Locker Rooms | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-167 | SOMS | 1 | Exterior Hose Bib- Wall by Loading Dock | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-168 | SOMS | 1 | Exterior Hose Bib- Wall by Kitchen Door | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-169 | SOMS | 1 | Exterior Hose Bib- Wall by Loading Dock | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-170 | SOMS | 1 | Exterior Hose Bib- Wall by Loading Dock | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-171 | SOMS | 1 | Exterior Hose Bib- Wall by Loading Dock | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-172 | SOMS | 1 | Exterior Hose Bib- Wall by Loading Dock | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet. |
| 2021-SOMS-173 | SOMS | 1 | Exterior Hose Bib- Wall by Loading Dock | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Sampled | Not Applicable | Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet. |
| <i>This spreadsheet was last updated on 8-29-22</i> | | | | | | | | | | | |