

Idaho National Engineering and Environmental Laboratory

Task IV ARIES-AT FW/Blanket Design Safety Assessment

B. J. Merrill *

H. Y. Khater **

E. A. Mogahed **

**** INEEL Fusion Safety Program***

***** Fusion Technology Institute
University of Wisconsin-Madison***


ALPS/APEX Meeting, Scottsdale, AZ, November 4-9, 2001




Introduction

- **A preliminary safety assessment of the Task IV ARIES-AT FW/Blanket design has been completed**
- **Hesham Y. Khater performed the activation analysis with the DKR-PULSAR code (FENDL-2 activation cross section data) for 1 FPY operation at 10 MW/m² neutron wall loading**
- **Elsayed A. Mogahed performed decay heat-up calculations with ANSYS 5.5.1 finite element code for a loss-of-coolant accident (LOCA) and a loss-of-flow accident (LOFA)**
- **Information from both analyses was used to assess site boundary dose during two vacuum vessel (VV) bypass accident scenarios: loss-of-vacuum accident (LOVA) and an ex-vessel LOCA**


Decay Heat Comparison



Cross Section of ARIES-AT Power Core Configuration



Finite-Element Model




The Upper Half of the ARIES-AT Power Core is Considered




University of Wisconsin-Madison

Inboard temperature history For One Week

due to LOCA for APEX Solid Wall Concept




A Comparison between LOCA Results of ARIES-AT ($\Gamma \approx 5 \text{ MW/m}^2$) and APEX Dry Wall ($\Gamma \approx 10 \text{ MW/m}^2$)



University of
 Wisconsin-Madison

1

1 day



APEX-Solid_WALL_LOCA,-Base Case,VV-ITemp=100C


ANSYS 5.5.1
 OCT 25 2001
 11:39:01
 PLOT NO. 12
 NODAL SOLUTION
 TIME=86400
 TEMP
 SMN =20
 SMX =1688
 20
 205.344
 390.687
 576.031
 761.375
 946.719
 1132
 1317
 1503
 1688

Temperature distribution

LOCA Analysis for APEX Dry Wall Concept

1

1 Week



APEX-Solid_WALL_LOCA,-Base Case,VV-ITemp=100C

ANSYS 5.5.1
 OCT 25 2001
 11:39:02
 PLOT NO. 18
 NODAL SOLUTION
 TIME=604800
 TEMP
 SMN =20
 SMX =945.817
 20
 122.869
 225.737
 328.606
 431.474
 534.343
 637.212
 740.08
 842.949
 945.817

N. Wall Loading
 10 MW/m²



University of
 Wisconsin-Madison


APEX Drywall Inventories and Allowable Releases

Radionuclides	Inventory	Release Limit for 10 mSv at 1 km (worst case weather- F & 1m/s)	
		Ground Release	Elevated Release (100 m stack)
Tritium as HTO	180 g	15 g	130 g
Activated W dust	10-100 kg	300 g	3450 g
Hg-203	5100 Ci/m³	2500 Ci (0.18 g)	25,000 Ci
Po-210	1380 Ci/m³	2.5 Ci (0.03 g)	25 Ci




Two vacuum vessel bypass accident scenarios examined:

- **Complete-loss-of-power accident initiating a plasma disruption that fails VV creating loss-of-vacuum accident (LOVA)**
- **Ex-vessel loss-of-coolant accident (LOCA) creating a LiPb pool in a confinement building room**

Bypass Accident Scenarios Analyzed



LOVA Bypass Accident Results



Ex-vessel LOCA Bypass Accident Results



- Spill volume 125 m³, surface area in lower function area (LFA) of 525 m²
- Mobilization of Po-210 by surface evaporation of PbPo from Schipakin data (P_{sat}(T) is vapor pressure of PbPo in mm of Hg, y_{Po-210} is mole fraction)

$$\Gamma(\text{Ci}/\text{cm}^2 - \text{hr}) = y_{\text{Po-210}} 3.0 \times 10^5 P_{\text{sat}}(T) \sqrt{1000/T}$$

- Mobilization of Hg-203 limited only by diffusion of Hg-203 to pool surface


$$\Gamma(\#/m^2 - s) = -D_{\text{Hg-203}} \frac{\partial C_{\text{Hg-203}}}{\partial x}$$

- Hg-203 surface concentration equals zero, Po-210 also limited by diffusion if surface evaporation is too large



Ex-vessel LOCA Bypass Accident Mobilization Results

- Hg-203 - confinement factors of 25 for ground release, 2.5 for elevated release or isolation in 1 hr, 5.5 hrs respectively
- Po-210 - confinement factors of 1650 for ground release, 165 for elevated release, or immediate isolation
- Online Po-210 cleanup from 30 PPB to 0.018 PPB ($< 1 \text{ Ci/m}^3$)
- Online Hg-203 cleanup from 37 PPB to 1.5 PPB



Summary & Conclusions

- Maximum temperatures are:

Accident	IB-VV SS	IB-FW SiC	OB-FW SiC	Div W
LOCA	824	1063	1153	1148
LOFA	847	1083	1194	1100

- Only concern may possibly be VV, but SS temperatures are less than ITER allowable ($0.7 \times T_{\text{melt}} = 960^{\circ}\text{C}$)
- In-vessel inventory release (HTO, W dust) are not a concern regarding ground level release limit if isolation occurs within 5 hrs
- Ex-vessel inventory release (Po-210, Hg-203) is a concern and online cleanup (if possible) of isotopes should solve problem